LISTING SERVICE

LISTING No.   7271-1394:103   Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Apollo Fire Detectors, 1749 E. Highwood, Pontiac MI 48340
          Contact: Robert Skaggs (810) 332-3900

DESIGN: Model 55000-550 ionization type smoke detector with Model 45681-210 mounting base.
          Refer to listee's data sheet for additional detailed product description and operational
          considerations.

RATING: Electrical: 17 - 28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances
          and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a ionization smoke detector and mounting base for use with separately listed
          compatible fire alarm control units.

04-17-95

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2002**   *Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
          Program Manager